



STATE OF TENNESSEE  
TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
COOKEVILLE ENVIRONMENTAL FIELD OFFICE

Phone 931-520-6688

1221 South Willow Avenue  
Cookeville, Tennessee 38506  
Statewide 1-888-891-8332

Fax 931-432-6952

February 7, 2017

Mr. John Ford, President  
BonDeCroft Utility District  
8756 Crossville Highway  
Sparta, Tennessee 38583

RE: **Sanitary Survey Community System**  
BonDeCroft Utility District  
PWSID #000653  
White County, Tennessee

Dear Mr. Ford:

On January 31, 2017, David Phillips from the Division of Water Resources (DWR) visited BonDeCroft Utility District and performed a Sanitary Survey. The Survey consisted of a records review to document the operational performance of the system and an on-site inspection of the distribution system. The Survey covered the time period from October 22, 2015 to January 31, 2017. The Division would like to thank you, Danny Brock, and staff for your courtesy, willingness to work with the Division, and timely responses to Division requests. In accordance with the Sanitary Survey Manual the BonDeCroft System earned 599 points out of a possible 599 points for a numerical score of one hundred percent (100%). This rating retains the BonDeCroft Water System in the State's "Approved" category.

**General Observations, Comments, and Other Recommendations**

1. The BonDeCroft Utility District now has 1,506 connections serving an estimated population of 3,795. The number of required bacteriological samples taken from the distribution system remains four (4) per month.

Mr. John Ford  
President BonDeCroft Utility District  
February 7, 2017  
Page 2

2. In accordance with Rule 0400-45-01-.14(l)(a), State approval for the analysis of turbidity, Free chlorine residual, pH, and alkalinity is hereby granted to Danny Brock. This approval is effective until the next survey and is contingent upon proper operation of analysis equipment.

Again, I would like to thank the BonDeCroft Utility District personnel for their assistance and courtesy. If you have any questions or need additional information, please contact me or David Phillips at the Cookeville Environmental Office.

Sincerely,



Johnny K. Walker  
Environmental Program Manager  
Cookeville Environmental Field Office  
Division of Water Resources

cc: Danny Brock, Manager  
White County Health Department  
Nashville Central Office  
File